

Table of Contents

**07.01.06 - RULES GOVERNING THE USE OF NATIONAL ELECTRICAL CODE
DIVISION OF BUILDING SAFETY**

000. LEGAL AUTHORITY. 2

001. TITLE AND SCOPE. 2

002. WRITTEN INTERPRETATIONS. 2

003. ADMINISTRATIVE APPEALS. 2

004. -- 010. (RESERVED). 2

011. NATIONAL ELECTRICAL CODE, 2002 EDITION..... 2

012. -- 999. (RESERVED). 2

**IDAPA 07
TITLE 01
CHAPTER 06**

**07.01.06 - RULES GOVERNING THE USE OF NATIONAL ELECTRICAL CODE
DIVISION OF BUILDING SAFETY**

000. LEGAL AUTHORITY.

The Idaho Electrical Board is authorized under Section 54-1001, Idaho Code, to adopt rules concerning the use of the National Electrical Code. (2-26-93)

001. TITLE AND SCOPE.

These rules shall be cited as IDAPA 07.01.06, "Rules Governing the Use of National Electrical Code," Division of Building Safety. These rules prescribe which edition of the National Electrical Code will be administered by the Idaho Electrical Board. (2-26-93)

002. WRITTEN INTERPRETATIONS.

This agency has no written interpretations of this chapter. (2-26-93)

003. ADMINISTRATIVE APPEALS.

This chapter does not allow administrative relief of the provisions outlined herein. (2-26-93)

004. -- 010. (RESERVED).

011. NATIONAL ELECTRICAL CODE, 2002 EDITION.

01. Documents. Under the provisions of Section 54-1001, Idaho Code, the National Electrical Code, 2002 Edition, is hereby adopted for the state of Idaho and shall be in full force and effect on and after July 1, 2002, with the exception of Article 80 and the following: (5-3-03)

a. Compliance with Article 675.8(B) will include the additional requirement that a disconnecting means always be provided at the point of service from the utility no matter where the disconnecting means for the machine is located. (5-3-03)

b. Compliance with Article 550.32(B) shall limit installation of a service on a manufactured home to those homes manufactured after January 1, 1992. (5-3-03)

c. Compliance with Article 210.12(B) shall not apply to the fire/smoke alarm branch circuit outlet. (5-3-03)

02. Availability. This document is available at the office of the Division of Building Safety, Electrical Bureau 1090 E. Watertower St., Meridian, Idaho. (5-3-03)

012. -- 999. (RESERVED).

Subject Index

D

Documents, National Electrical Code
Incorporation 2

N

National Electrical Code, 2002
Edition 2